

EU-Type Examination Certificate

No. E6A 109906 0069 Rev. 01

Holder of Certificate: **Hiconics Eco-energy Drive Technology Co., Ltd.**

No.3 Boxing 2nd Road
Beijing Economic and Technological Development Zone
100176 Beijing
PEOPLE'S REPUBLIC OF CHINA

Product: **Electronic frequency converter
(Medium Voltage Drive)**

This EU-Type Examination Certificate is issued according to the Directive 2014/30/EU relating to electromagnetic compatibility. It confirms that the listed apparatus complies with such aspects of the requirements of the EMC directive as specified by the manufacturer or his authorized representative in the European Community and applies only to the sample and/or its technical documentation submitted for testing and certification. This Type Examination does not contain any statements pertaining to the EMC protection requirements governed by other laws which serve to implement EU Directives other than the aforementioned Directive 2014/30/EU.

For details see: www.tuvsud.com/ps-cert

Evaluation Report No.: 64.713.24.30757.02-(T)

Date, 2024-12-10



(Yury Oleinik)

EU-Type Examination Certificate

No. E6A 109906 0069 Rev. 01

Model(s):

HC1000S-110/00670,HC1000S-110/00860,HC1000S-110/01030,
 HC1000S-110/01190,HC1000S-110/01380,HC1000S-110/01550,
 HC1000S-110/01740,HC1000S-110/02040,HC1000S-110/02220,
 HC1000S-110/02580,HC1000S-110/02920,HC1000S-110/03430,
 HC1000S-110/03850,HC1000S-110/04390,HC1000S-110/04650,
 HC1000S-100/00275,HC1000S-100/00320,HC1000S-100/00350,
 HC1000S-100/00400,HC1000S-100/00450,HC1000S-100/00500,
 HC1000S-100/00560,HC1000S-100/00630,HC1000S-100/00700,
 HC1000S-100/00800,HC1000S-100/00900,HC1000S-100/01000,
 HC1000S-100/01150,HC1000S-100/01250,HC1000S-100/01400,
 HC1000S-100/01600,HC1000S-100/01800,HC1000S-100/02000,
 HC1000S-100/02250,HC1000S-100/02500,HC1000S-100/02800,
 HC1000S-100/03150,HC1000S-100/03500,HC1000S-100/04000,
 HC1000S-100/04500,HC1000S-066/00410,HC1000S-066/00520,
 HC1000S-066/00620,HC1000S-066/00710,HC1000S-066/00830,
 HC1000S-066/00930,HC1000S-066/01050,HC1000S-066/01230,
 HC1000S-066/01330,HC1000S-066/01550,HC1000S-066/01750,
 HC1000S-066/01870,HC1000S-066/02060,HC1000S-066/02310,
 HC1000S-066/02630,HC1000S-066/02800,HC1000S-060/00250,
 HC1000S-060/00315,HC1000S-060/00400,HC1000S-060/00500,
 HC1000S-060/00560,HC1000S-060/00630,HC1000S-060/00700,
 HC1000S-060/00800,HC1000S-060/00900,HC1000S-060/01000,
 HC1000S-060/01150,HC1000S-060/01250,HC1000S-060/01400,
 HC1000S-060/01600,HC1000S-060/01800,HC1000S-060/02000,
 HC1000S-060/02250,HC1000S-060/02500,HC1000S-416/00260,
 HC1000S-416/00330,HC1000S-416/00390,HC1000S-416/00450,
 HC1000S-416/00520,HC1000S-416/00590,HC1000S-416/00660,
 HC1000S-416/00780,HC1000S-416/00840,HC1000S-416/00980,
 HC1000S-416/01110,HC1000S-416/01180,HC1000S-416/01300,
 HC1000S-416/01460,HC1000S-416/01660,HC1000S-416/01860,
 HC1000S-033/00210,HC1000S-033/00260,HC1000S-033/00310,
 HC1000S-033/00360,HC1000S-033/00420,HC1000S-033/00470,
 HC1000S-033/00530,HC1000S-033/00620,HC1000S-033/00670,
 HC1000S-033/00780,HC1000S-033/00880,HC1000S-033/00940,
 HC1000S-033/01030,HC1000S-033/01160,HC1000S-033/01320,
 HC1000S-033/01480,HC1000-110/00670,HC1000-110/00860,
 HC1000-110/01030,HC1000-110/01190,HC1000-110/01380,
 HC1000-110/01550,HC1000-110/01740,HC1000-110/02040,
 HC1000-110/02220,HC1000-110/02580,HC1000-110/02920,
 HC1000-110/03430,HC1000-110/03850,HC1000-110/04390,
 HC1000-110/04650,HC1000-110/05430,HC1000-110/06100,
 HC1000-110/06760,HC1000-110/07530,HC1000-110/07500,
 HC1000-110/08500,HC1000-110/09140,HC1000-110/10500,
 HC1000-110/10700,HC1000-110/11800,HC1000-110/13000,
 HC1000-110/15600,HC1000-100/00275,HC1000-100/00320,
 HC1000-100/00350,HC1000-100/00400,HC1000-100/00450,
 HC1000-100/00500,HC1000-100/00560,HC1000-100/00630,
 HC1000-100/00700,HC1000-100/00800,HC1000-100/00900,
 HC1000-100/01000,HC1000-100/01150,HC1000-100/01250,
 HC1000-100/01400,HC1000-100/01600,HC1000-100/01800,
 HC1000-100/02000,HC1000-100/02250,HC1000-100/02500,
 HC1000-100/02800,HC1000-100/03150,HC1000-100/03500,

EU-Type Examination Certificate

No. E6A 109906 0069 Rev. 01

HC1000-100/04000,HC1000-100/04500,HC1000-100/05000,
HC1000-100/05650,HC1000-100/06300,HC1000-100/07000,
HC1000-100/07500,HC1000-100/08500,HC1000-100/09500,
HC1000-100/10700,HC1000-100/11800,HC1000-100/13300,
HC1000-100/14200,HC1000-066/00410,HC1000-066/00520,
HC1000-066/00620,HC1000-066/00710,HC1000-066/00830,
HC1000-066/00930,HC1000-066/01050,HC1000-066/01230,
HC1000-066/01330,HC1000-066/01550,HC1000-066/01750,
HC1000-066/01870,HC1000-066/02060,HC1000-066/02310,
HC1000-066/02630,HC1000-066/02800,HC1000-066/03260,
HC1000-066/03660,HC1000-066/04060,HC1000-066/04520,
HC1000-066/05000,HC1000-066/05490,HC1000-066/06290,
HC1000-066/07000,HC1000-066/07770,HC1000-066/09370,
HC1000-060/00250,HC1000-060/00315,HC1000-060/00400,
HC1000-060/00500,HC1000-060/00560,HC1000-060/00630,
HC1000-060/00700,HC1000-060/00800,HC1000-060/00900,
HC1000-060/01000,HC1000-060/01150,HC1000-060/01250,
HC1000-060/01400,HC1000-060/01600,HC1000-060/01800,
HC1000-060/02000,HC1000-060/02250,HC1000-060/02500,
HC1000-060/02800,HC1000-060/03200,HC1000-060/03500,
HC1000-060/04000,HC1000-060/04500,HC1000-060/05000,
HC1000-060/05600,HC1000-060/06300,HC1000-060/07000,
HC1000-060/07500,HC1000-060/08500,HC1000-416/00260,
HC1000-416/00330,HC1000-416/00390,HC1000-416/00450,
HC1000-416/00520,HC1000-416/00590,HC1000-416/00660,
HC1000-416/00780,HC1000-416/00840,HC1000-416/00980,
HC1000-416/01110,HC1000-416/01180,HC1000-416/01300,
HC1000-416/01460,HC1000-416/01660,HC1000-416/01860,
HC1000-416/02050,HC1000-416/02300,HC1000-416/02560,
HC1000-416/02850,HC1000-416/03125,HC1000-416/03460,
HC1000-416/03960,HC1000-416/04300,HC1000-416/04900,
HC1000-416/05910,HC1000-033/00210,HC1000-033/00260,
HC1000-033/00310,HC1000-033/00360,HC1000-033/00420,
HC1000-033/00470,HC1000-033/00530,HC1000-033/00620,
HC1000-033/00670,HC1000-033/00780,HC1000-033/00880,
HC1000-033/00940,HC1000-033/01030,HC1000-033/01160,
HC1000-033/01320,HC1000-033/01480,HC1000-033/01630,
HC1000-033/01830,HC1000-033/02030,HC1000-033/02260,
HC1000-033/02500,HC1000-033/02740,HC1000-033/03140,
HC1000-033/03500,HC1000-033/03890,HC1000-033/04690

EU-Type Examination Certificate

No. E6A 109906 0069 Rev. 01

Description of Object:

Rating : See pages 5-11

Remark:

All aspects of the essential requirements were assessed.

The report is only valid if no transmitting radio equipment is included in the device (BT,WiFi, 4G, RFID.etc).

Environments:C4 and second enviroments

Tested

EN IEC 61800-3:2023

according to:

EU-Type Examination Certificate

No. E6A 109906 0069 Rev. 01

Model list

Model	Rated input voltage	Rated input frequency	Rated capacity	Rated output voltage	Output frequency range
HC1000S-110/00670	11kV	50/60Hz	670kVA	11kV	0-120Hz
HC1000S-110/00860	11kV	50/60Hz	860kVA	11kV	0-120Hz
HC1000S-110/01030	11kV	50/60Hz	1030kVA	11kV	0-120Hz
HC1000S-110/01190	11kV	50/60Hz	1190kVA	11kV	0-120Hz
HC1000S-110/01380	11kV	50/60Hz	1380kVA	11kV	0-120Hz
HC1000S-110/01550	11kV	50/60Hz	1550kVA	11kV	0-120Hz
HC1000S-110/01740	11kV	50/60Hz	1740kVA	11kV	0-120Hz
HC1000S-110/02040	11kV	50/60Hz	2040kVA	11kV	0-120Hz
HC1000S-110/02220	11kV	50/60Hz	2220kVA	11kV	0-120Hz
HC1000S-110/02580	11kV	50/60Hz	2580kVA	11kV	0-120Hz
HC1000S-110/02920	11kV	50/60Hz	2920kVA	11kV	0-120Hz
HC1000S-110/03430	11kV	50/60Hz	3430kVA	11kV	0-120Hz
HC1000S-110/03850	11kV	50/60Hz	3850kVA	11kV	0-120Hz
HC1000S-110/04390	11kV	50/60Hz	4390kVA	11kV	0-120Hz
HC1000S-110/04650	11kV	50/60Hz	4560kVA	11kV	0-120Hz
HC1000S-100/00275	10kV	50/60Hz	275kVA	10kV	0-120Hz
HC1000S-100/00320	10kV	50/60Hz	320kVA	10kV	0-120Hz
HC1000S-100/00350	10kV	50/60Hz	350kVA	10kV	0-120Hz
HC1000S-100/00400	10kV	50/60Hz	400kVA	10kV	0-120Hz
HC1000S-100/00450	10kV	50/60Hz	450kVA	10kV	0-120Hz
HC1000S-100/00500	10kV	50/60Hz	500kVA	10kV	0-120Hz
HC1000S-100/00560	10kV	50/60Hz	560kVA	10kV	0-120Hz
HC1000S-100/00630	10kV	50/60Hz	630kVA	10kV	0-120Hz
HC1000S-100/00700	10kV	50/60Hz	700kVA	10kV	0-120Hz
HC1000S-100/00800	10kV	50/60Hz	800kVA	10kV	0-120Hz
HC1000S-100/00900	10kV	50/60Hz	900kVA	10kV	0-120Hz
HC1000S-100/01000	10kV	50/60Hz	1000kVA	10kV	0-120Hz
HC1000S-100/01150	10kV	50/60Hz	1150kVA	10kV	0-120Hz
HC1000S-100/01250	10kV	50/60Hz	1250kVA	10kV	0-120Hz
HC1000S-100/01400	10kV	50/60Hz	1400kVA	10kV	0-120Hz
HC1000S-100/01600	10kV	50/60Hz	1600kVA	10kV	0-120Hz
HC1000S-100/01800	10kV	50/60Hz	1800kVA	10kV	0-120Hz
HC1000S-100/02000	10kV	50/60Hz	2000kVA	10kV	0-120Hz
HC1000S-100/02250	10kV	50/60Hz	2250kVA	10kV	0-120Hz
HC1000S-100/02500	10kV	50/60Hz	2500kVA	10kV	0-120Hz
HC1000S-100/02800	10kV	50/60Hz	2800kVA	10kV	0-120Hz
HC1000S-100/03150	10kV	50/60Hz	3150kVA	10kV	0-120Hz
HC1000S-100/03500	10kV	50/60Hz	3500kVA	10kV	0-120Hz

EU-Type Examination Certificate

No. E6A 109906 0069 Rev. 01

HC1000S-100/04000	10kV	50/60Hz	4000kVA	10kV	0-120Hz
HC1000S-100/04500	10kV	50/60Hz	4500kVA	10kV	0-120Hz
HC1000S-066/00410	6.6kV	50/60Hz	410kVA	6.6kV	0-120Hz
HC1000S-066/00520	6.6kV	50/60Hz	520kVA	6.6kV	0-120Hz
HC1000S-066/00620	6.6kV	50/60Hz	620kVA	6.6kV	0-120Hz
HC1000S-066/00710	6.6kV	50/60Hz	710kVA	6.6kV	0-120Hz
HC1000S-066/00830	6.6kV	50/60Hz	830kVA	6.6kV	0-120Hz
HC1000S-066/00930	6.6kV	50/60Hz	930kVA	6.6kV	0-120Hz
HC1000S-066/01050	6.6kV	50/60Hz	1050kVA	6.6kV	0-120Hz
HC1000S-066/01230	6.6kV	50/60Hz	1230kVA	6.6kV	0-120Hz
HC1000S-066/01330	6.6kV	50/60Hz	1330kVA	6.6kV	0-120Hz
HC1000S-066/01550	6.6kV	50/60Hz	1550kVA	6.6kV	0-120Hz
HC1000S-066/01750	6.6kV	50/60Hz	1750kVA	6.6kV	0-120Hz
HC1000S-066/01870	6.6kV	50/60Hz	1870kVA	6.6kV	0-120Hz
HC1000S-066/02060	6.6kV	50/60Hz	2060kVA	6.6kV	0-120Hz
HC1000S-066/02310	6.6kV	50/60Hz	2310kVA	6.6kV	0-120Hz
HC1000S-066/02630	6.6kV	50/60Hz	2630kVA	6.6kV	0-120Hz
HC1000S-066/02800	6.6kV	50/60Hz	2800kVA	6.6kV	0-120Hz
HC1000S-060/00250	6kV	50/60Hz	250kVA	6kV	0-120Hz
HC1000S-060/00315	6kV	50/60Hz	315kVA	6kV	0-120Hz
HC1000S-060/00400	6kV	50/60Hz	400kVA	6kV	0-120Hz
HC1000S-060/00500	6kV	50/60Hz	500kVA	6kV	0-120Hz
HC1000S-060/00560	6kV	50/60Hz	560kVA	6kV	0-120Hz
HC1000S-060/00630	6kV	50/60Hz	630kVA	6kV	0-120Hz
HC1000S-060/00700	6kV	50/60Hz	700kVA	6kV	0-120Hz
HC1000S-060/00800	6kV	50/60Hz	800kVA	6kV	0-120Hz
HC1000S-060/00900	6kV	50/60Hz	900kVA	6kV	0-120Hz
HC1000S-060/01000	6kV	50/60Hz	1000kVA	6kV	0-120Hz
HC1000S-060/01150	6kV	50/60Hz	1150kVA	6kV	0-120Hz
HC1000S-060/01250	6kV	50/60Hz	1250kVA	6kV	0-120Hz
HC1000S-060/01400	6kV	50/60Hz	1400kVA	6kV	0-120Hz
HC1000S-060/01600	6kV	50/60Hz	1600kVA	6kV	0-120Hz
HC1000S-060/01800	6kV	50/60Hz	1800kVA	6kV	0-120Hz
HC1000S-060/02000	6kV	50/60Hz	2000kVA	6kV	0-120Hz
HC1000S-060/02250	6kV	50/60Hz	2250kVA	6kV	0-120Hz
HC1000S-060/02500	6kV	50/60Hz	2500kVA	6kV	0-120Hz
HC1000S-416/00260	4.16kV	50/60Hz	260kVA	4.16kV	0-120Hz
HC1000S-416/00330	4.16kV	50/60Hz	330kVA	4.16kV	0-120Hz
HC1000S-416/00390	4.16kV	50/60Hz	390kVA	4.16kV	0-120Hz
HC1000S-416/00450	4.16kV	50/60Hz	450kVA	4.16kV	0-120Hz
HC1000S-416/00520	4.16kV	50/60Hz	520kVA	4.16kV	0-120Hz
HC1000S-416/00590	4.16kV	50/60Hz	590kVA	4.16kV	0-120Hz

Page 6 of 11

TÜV SÜD Product Service GmbH is notified Body to the Directive 2014/30/EU relating to electromagnetic compatibility with the identification number 0123.

EU-Type Examination Certificate

No. E6A 109906 0069 Rev. 01

HC1000S-416/00660	4.16kV	50/60Hz	660kVA	4.16kV	0-120Hz
HC1000S-416/00780	4.16kV	50/60Hz	780kVA	4.16kV	0-120Hz
HC1000S-416/00840	4.16kV	50/60Hz	840kVA	4.16kV	0-120Hz
HC1000S-416/00980	4.16kV	50/60Hz	980kVA	4.16kV	0-120Hz
HC1000S-416/01110	4.16kV	50/60Hz	1110kVA	4.16kV	0-120Hz
HC1000S-416/01180	4.16kV	50/60Hz	1180kVA	4.16kV	0-120Hz
HC1000S-416/01300	4.16kV	50/60Hz	1300kVA	4.16kV	0-120Hz
HC1000S-416/01460	4.16kV	50/60Hz	1460kVA	4.16kV	0-120Hz
HC1000S-416/01660	4.16kV	50/60Hz	1660kVA	4.16kV	0-120Hz
HC1000S-416/01860	4.16kV	50/60Hz	1860kVA	4.16kV	0-120Hz
HC1000S-033/00210	3.3kV	50/60Hz	210kVA	3.3kV	0-120Hz
HC1000S-033/00260	3.3kV	50/60Hz	260kVA	3.3kV	0-120Hz
HC1000S-033/00310	3.3kV	50/60Hz	310kVA	3.3kV	0-120Hz
HC1000S-033/00360	3.3kV	50/60Hz	360kVA	3.3kV	0-120Hz
HC1000S-033/00420	3.3kV	50/60Hz	420kVA	3.3kV	0-120Hz
HC1000S-033/00470	3.3kV	50/60Hz	470kVA	3.3kV	0-120Hz
HC1000S-033/00530	3.3kV	50/60Hz	530kVA	3.3kV	0-120Hz
HC1000S-033/00620	3.3kV	50/60Hz	620kVA	3.3kV	0-120Hz
HC1000S-033/00670	3.3kV	50/60Hz	670kVA	3.3kV	0-120Hz
HC1000S-033/00780	3.3kV	50/60Hz	780kVA	3.3kV	0-120Hz
HC1000S-033/00880	3.3kV	50/60Hz	880kVA	3.3kV	0-120Hz
HC1000S-033/00940	3.3kV	50/60Hz	940kVA	3.3kV	0-120Hz
HC1000S-033/01030	3.3kV	50/60Hz	1030kVA	3.3kV	0-120Hz
HC1000S-033/01160	3.3kV	50/60Hz	1160kVA	3.3kV	0-120Hz
HC1000S-033/01320	3.3kV	50/60Hz	1320kVA	3.3kV	0-120Hz
HC1000S-033/01480	3.3kV	50/60Hz	1480kVA	3.3kV	0-120Hz
HC1000-110/00670	11kV	50/60Hz	670kVA	11kV	0-120Hz
HC1000-110/00860	11kV	50/60Hz	860 kVA	11kV	0-120Hz
HC1000-110/01030	11kV	50/60Hz	1030kVA	11kV	0-120Hz
HC1000-110/01190	11kV	50/60Hz	1190kVA	11kV	0-120Hz
HC1000-110/01380	11kV	50/60Hz	1380kVA	11kV	0-120Hz
HC1000-110/01550	11kV	50/60Hz	1550kVA	11kV	0-120Hz
HC1000-110/01740	11kV	50/60Hz	1740kVA	11kV	0-120Hz
HC1000-110/02040	11kV	50/60Hz	2040kVA	11kV	0-120Hz
HC1000-110/02220	11kV	50/60Hz	2220kVA	11kV	0-120Hz
HC1000-110/02580	11kV	50/60Hz	2580kVA	11kV	0-120Hz
HC1000-110/02920	11kV	50/60Hz	2920kVA	11kV	0-120Hz
HC1000-110/03430	11kV	50/60Hz	3430kVA	11kV	0-120Hz
HC1000-110/03850	11kV	50/60Hz	3850kVA	11kV	0-120Hz
HC1000-110/04390	11kV	50/60Hz	4390kVA	11kV	0-120Hz
HC1000-110/04650	11kV	50/60Hz	4650kVA	11kV	0-120Hz
HC1000-110/05430	11kV	50/60Hz	5430kVA	11kV	0-120Hz

Page 7 of 11

TÜV SÜD Product Service GmbH is notified Body to the Directive 2014/30/EU relating to electromagnetic compatibility with the identification number 0123.

EU-Type Examination Certificate

No. E6A 109906 0069 Rev. 01

HC1000-110/06100	11kV	50/60Hz	6100kVA	11kV	0-120Hz
HC1000-110/06760	11kV	50/60Hz	6760kVA	11kV	0-120Hz
HC1000-110/07530	11kV	50/60Hz	7530kVA	11kV	0-120Hz
HC1000-110/07500	11kV	50/60Hz	7500kVA	11kV	0-120Hz
HC1000-110/08500	11kV	50/60Hz	8500kVA	11kV	0-120Hz
HC1000-110/09140	11kV	50/60Hz	9140kVA	11kV	0-120Hz
HC1000-110/10500	11kV	50/60Hz	10500kVA	11kV	0-120Hz
HC1000-110/10700	11kV	50/60Hz	10700kVA	11kV	0-120Hz
HC1000-110/11800	11kV	50/60Hz	11800kVA	11kV	0-120Hz
HC1000-110/13000	11kV	50/60Hz	13000kVA	11kV	0-120Hz
HC1000-110/15600	11kV	50/60Hz	15600kVA	11kV	0-120Hz
HC1000-100/00275	10 kV	50/60Hz	275kVA	10 kV	0-120Hz
HC1000-100/00320	10 kV	50/60Hz	320kVA	10 kV	0-120Hz
HC1000-100/00350	10 kV	50/60Hz	350kVA	10 kV	0-120Hz
HC1000-100/00400	10 kV	50/60Hz	400kVA	10 kV	0-120Hz
HC1000-100/00450	10 kV	50/60Hz	450kVA	10 kV	0-120Hz
HC1000-100/00500	10 kV	50/60Hz	500kVA	10 kV	0-120Hz
HC1000-100/00560	10 kV	50/60Hz	560kVA	10 kV	0-120Hz
HC1000-100/00630	10 kV	50/60Hz	630kVA	10 kV	0-120Hz
HC1000-100/00700	10 kV	50/60Hz	700kVA	10 kV	0-120Hz
HC1000-100/00800	10 kV	50/60Hz	800kVA	10 kV	0-120Hz
HC1000-100/00900	10 kV	50/60Hz	900kVA	10 kV	0-120Hz
HC1000-100/01000	10 kV	50/60Hz	1000kVA	10 kV	0-120Hz
HC1000-100/01150	10 kV	50/60Hz	1150kVA	10 kV	0-120Hz
HC1000-100/01250	10 kV	50/60Hz	1250kVA	10 kV	0-120Hz
HC1000-100/01400	10 kV	50/60Hz	1400kVA	10 kV	0-120Hz
HC1000-100/01600	10 kV	50/60Hz	1600kVA	10 kV	0-120Hz
HC1000-100/01800	10 kV	50/60Hz	1800kVA	10 kV	0-120Hz
HC1000-100/02000	10 kV	50/60Hz	2000kVA	10 kV	0-120Hz
HC1000-100/02250	10 kV	50/60Hz	2250kVA	10 kV	0-120Hz
HC1000-100/02500	10 kV	50/60Hz	2500kVA	10 kV	0-120Hz
HC1000-100/02800	10 kV	50/60Hz	2800kVA	10 kV	0-120Hz
HC1000-100/03150	10 kV	50/60Hz	3150kVA	10 kV	0-120Hz
HC1000-100/03500	10 kV	50/60Hz	3500kVA	10 kV	0-120Hz
HC1000-100/04000	10 kV	50/60Hz	4000kVA	10 kV	0-120Hz
HC1000-100/04500	10 kV	50/60Hz	4500kVA	10 kV	0-120Hz
HC1000-100/05000	10 kV	50/60Hz	5000kVA	10 kV	0-120Hz
HC1000-100/05650	10 kV	50/60Hz	5650kVA	10 kV	0-120Hz
HC1000-100/06300	10 kV	50/60Hz	6300kVA	10 kV	0-120Hz
HC1000-100/07000	10 kV	50/60Hz	7000kVA	10 kV	0-120Hz
HC1000-100/07500	10 kV	50/60Hz	7500kVA	10 kV	0-120Hz
HC1000-100/08500	10 kV	50/60Hz	8500kVA	10 kV	0-120Hz

Page 8 of 11

TÜV SÜD Product Service GmbH is notified Body to the Directive 2014/30/EU relating to electromagnetic compatibility with the identification number 0123.

EU-Type Examination Certificate

No. E6A 109906 0069 Rev. 01

HC1000-100/09500	10 kV	50/60Hz	9500kVA	10 kV	0-120Hz
HC1000-100/10700	10 kV	50/60Hz	10700kVA	10 kV	0-120Hz
HC1000-100/11800	10 kV	50/60Hz	11800kVA	10 kV	0-120Hz
HC1000-100/13300	10 kV	50/60Hz	13300kVA	10 kV	0-120Hz
HC1000-100/14200	10 kV	50/60Hz	14200kVA	10 kV	0-120Hz
HC1000-066/00410	6.6 kV	50/60Hz	410kVA	6.6 kV	0-120Hz
HC1000-066/00520	6.6 kV	50/60Hz	520kVA	6.6 kV	0-120Hz
HC1000-066/00620	6.6 kV	50/60Hz	620kVA	6.6 kV	0-120Hz
HC1000-066/00710	6.6 kV	50/60Hz	710kVA	6.6 kV	0-120Hz
HC1000-066/00830	6.6 kV	50/60Hz	830kVA	6.6 kV	0-120Hz
HC1000-066/00930	6.6 kV	50/60Hz	930kVA	6.6 kV	0-120Hz
HC1000-066/01050	6.6 kV	50/60Hz	1050kVA	6.6 kV	0-120Hz
HC1000-066/01230	6.6 kV	50/60Hz	1230kVA	6.6 kV	0-120Hz
HC1000-066/01330	6.6 kV	50/60Hz	1330kVA	6.6 kV	0-120Hz
HC1000-066/01550	6.6 kV	50/60Hz	1550kVA	6.6 kV	0-120Hz
HC1000-066/01750	6.6 kV	50/60Hz	1750kVA	6.6 kV	0-120Hz
HC1000-066/01870	6.6 kV	50/60Hz	1870kVA	6.6 kV	0-120Hz
HC1000-066/02060	6.6 kV	50/60Hz	2060kVA	6.6 kV	0-120Hz
HC1000-066/02310	6.6 kV	50/60Hz	2310kVA	6.6 kV	0-120Hz
HC1000-066/02630	6.6 kV	50/60Hz	2630kVA	6.6 kV	0-120Hz
HC1000-066/02800	6.6 kV	50/60Hz	2800kVA	6.6 kV	0-120Hz
HC1000-066/03260	6.6 kV	50/60Hz	3260kVA	6.6 kV	0-120Hz
HC1000-066/03660	6.6 kV	50/60Hz	3660kVA	6.6 kV	0-120Hz
HC1000-066/04060	6.6 kV	50/60Hz	4060kVA	6.6 kV	0-120Hz
HC1000-066/04520	6.6 kV	50/60Hz	4520kVA	6.6 kV	0-120Hz
HC1000-066/05000	6.6 kV	50/60Hz	5000kVA	6.6 kV	0-120Hz
HC1000-066/05490	6.6 kV	50/60Hz	5490kVA	6.6 kV	0-120Hz
HC1000-066/06290	6.6 kV	50/60Hz	6290kVA	6.6 kV	0-120Hz
HC1000-066/07000	6.6 kV	50/60Hz	7000kVA	6.6 kV	0-120Hz
HC1000-066/07770	6.6 kV	50/60Hz	7770kVA	6.6 kV	0-120Hz
HC1000-066/09370	6.6 kV	50/60Hz	9370kVA	6.6 kV	0-120Hz
HC1000-060/00250	6 kV	50/60Hz	250kVA	6 kV	0-120Hz
HC1000-060/00315	6 kV	50/60Hz	315kVA	6 kV	0-120Hz
HC1000-060/00400	6 kV	50/60Hz	400kVA	6 kV	0-120Hz
HC1000-060/00500	6 kV	50/60Hz	500kVA	6 kV	0-120Hz
HC1000-060/00560	6 kV	50/60Hz	560kVA	6 kV	0-120Hz
HC1000-060/00630	6 kV	50/60Hz	630kVA	6 kV	0-120Hz
HC1000-060/00700	6 kV	50/60Hz	700kVA	6 kV	0-120Hz
HC1000-060/00800	6 kV	50/60Hz	800kVA	6 kV	0-120Hz
HC1000-060/00900	6 kV	50/60Hz	900kVA	6 kV	0-120Hz
HC1000-060/01000	6 kV	50/60Hz	1000kVA	6 kV	0-120Hz
HC1000-060/01150	6 kV	50/60Hz	1150kVA	6 kV	0-120Hz

Page 9 of 11

TÜV SÜD Product Service GmbH is notified Body to the Directive 2014/30/EU relating to electromagnetic compatibility with the identification number 0123.

EU-Type Examination Certificate

No. E6A 109906 0069 Rev. 01

HC1000-060/01250	6 kV	50/60Hz	1250kVA	6 kV	0-120Hz
HC1000-060/01400	6 kV	50/60Hz	1400kVA	6 kV	0-120Hz
HC1000-060/01600	6 kV	50/60Hz	1600kVA	6 kV	0-120Hz
HC1000-060/01800	6 kV	50/60Hz	1800kVA	6 kV	0-120Hz
HC1000-060/02000	6 kV	50/60Hz	2000kVA	6 kV	0-120Hz
HC1000-060/02250	6 kV	50/60Hz	2250kVA	6 kV	0-120Hz
HC1000-060/02500	6 kV	50/60Hz	2500kVA	6 kV	0-120Hz
HC1000-060/02800	6 kV	50/60Hz	2800kVA	6 kV	0-120Hz
HC1000-060/03200	6 kV	50/60Hz	3200kVA	6 kV	0-120Hz
HC1000-060/03500	6 kV	50/60Hz	3500kVA	6 kV	0-120Hz
HC1000-060/04000	6 kV	50/60Hz	4000kVA	6 kV	0-120Hz
HC1000-060/04500	6 kV	50/60Hz	4500kVA	6 kV	0-120Hz
HC1000-060/05000	6 kV	50/60Hz	5000kVA	6 kV	0-120Hz
HC1000-060/05600	6 kV	50/60Hz	5600kVA	6 kV	0-120Hz
HC1000-060/06300	6 kV	50/60Hz	6300kVA	6 kV	0-120Hz
HC1000-060/07000	6 kV	50/60Hz	7000kVA	6 kV	0-120Hz
HC1000-060/07500	6 kV	50/60Hz	7500kVA	6 kV	0-120Hz
HC1000-060/08500	6 kV	50/60Hz	8500kVA	6 kV	0-120Hz
HC1000-416/00260	4.16 kV	50/60Hz	260kVA	4.16 kV	0-120Hz
HC1000-416/00330	4.16 kV	50/60Hz	330kVA	4.16 kV	0-120Hz
HC1000-416/00390	4.16 kV	50/60Hz	390kVA	4.16 kV	0-120Hz
HC1000-416/00450	4.16 kV	50/60Hz	450kVA	4.16 kV	0-120Hz
HC1000-416/00520	4.16 kV	50/60Hz	520kVA	4.16 kV	0-120Hz
HC1000-416/00590	4.16 kV	50/60Hz	590kVA	4.16 kV	0-120Hz
HC1000-416/00660	4.16 kV	50/60Hz	660kVA	4.16 kV	0-120Hz
HC1000-416/00780	4.16 kV	50/60Hz	780kVA	4.16 kV	0-120Hz
HC1000-416/00840	4.16 kV	50/60Hz	840kVA	4.16 kV	0-120Hz
HC1000-416/00980	4.16 kV	50/60Hz	980kVA	4.16 kV	0-120Hz
HC1000-416/01110	4.16 kV	50/60Hz	1110kVA	4.16 kV	0-120Hz
HC1000-416/01180	4.16 kV	50/60Hz	1180kVA	4.16 kV	0-120Hz
HC1000-416/01300	4.16 kV	50/60Hz	1300kVA	4.16 kV	0-120Hz
HC1000-416/01460	4.16 kV	50/60Hz	1460kVA	4.16 kV	0-120Hz
HC1000-416/01660	4.16 kV	50/60Hz	1660kVA	4.16 kV	0-120Hz
HC1000-416/01860	4.16 kV	50/60Hz	1860kVA	4.16 kV	0-120Hz
HC1000-416/02050	4.16 kV	50/60Hz	2050kVA	4.16 kV	0-120Hz
HC1000-416/02300	4.16 kV	50/60Hz	2300kVA	4.16 kV	0-120Hz
HC1000-416/02560	4.16 kV	50/60Hz	2560kVA	4.16 kV	0-120Hz
HC1000-416/02850	4.16 kV	50/60Hz	2850kVA	4.16 kV	0-120Hz
HC1000-416/03125	4.16 kV	50/60Hz	3125kVA	4.16 kV	0-120Hz
HC1000-416/03460	4.16 kV	50/60Hz	3460kVA	4.16 kV	0-120Hz
HC1000-416/03960	4.16 kV	50/60Hz	3960kVA	4.16 kV	0-120Hz
HC1000-416/04300	4.16 kV	50/60Hz	4300kVA	4.16 kV	0-120Hz

EU-Type Examination Certificate

No. E6A 109906 0069 Rev. 01

HC1000-416/04900	4.16 kV	50/60Hz	4900kVA	4.16 kV	0-120Hz
HC1000-416/05910	4.16 kV	50/60Hz	5910kVA	4.16 kV	0-120Hz
HC1000-033/00210	3.3 kV	50/60Hz	210kVA	3.3 kV	0-120Hz
HC1000-033/00260	3.3 kV	50/60Hz	260kVA	3.3 kV	0-120Hz
HC1000-033/00310	3.3 kV	50/60Hz	310kVA	3.3 kV	0-120Hz
HC1000-033/00360	3.3 kV	50/60Hz	360kVA	3.3 kV	0-120Hz
HC1000-033/00420	3.3 kV	50/60Hz	420kVA	3.3 kV	0-120Hz
HC1000-033/00470	3.3 kV	50/60Hz	470kVA	3.3 kV	0-120Hz
HC1000-033/00530	3.3 kV	50/60Hz	530kVA	3.3 kV	0-120Hz
HC1000-033/00620	3.3 kV	50/60Hz	620kVA	3.3 kV	0-120Hz
HC1000-033/00670	3.3 kV	50/60Hz	670kVA	3.3 kV	0-120Hz
HC1000-033/00780	3.3 kV	50/60Hz	780kVA	3.3 kV	0-120Hz
HC1000-033/00880	3.3 kV	50/60Hz	880kVA	3.3 kV	0-120Hz
HC1000-033/00940	3.3 kV	50/60Hz	940kVA	3.3 kV	0-120Hz
HC1000-033/01030	3.3 kV	50/60Hz	1030kVA	3.3 kV	0-120Hz
HC1000-033/01160	3.3 kV	50/60Hz	1160kVA	3.3 kV	0-120Hz
HC1000-033/01320	3.3 kV	50/60Hz	1320kVA	3.3 kV	0-120Hz
HC1000-033/01480	3.3 kV	50/60Hz	1480kVA	3.3 kV	0-120Hz
HC1000-033/01630	3.3 kV	50/60Hz	1630kVA	3.3 kV	0-120Hz
HC1000-033/01830	3.3 kV	50/60Hz	1830kVA	3.3 kV	0-120Hz
HC1000-033/02030	3.3 kV	50/60Hz	2030kVA	3.3 kV	0-120Hz
HC1000-033/02260	3.3 kV	50/60Hz	2260kVA	3.3 kV	0-120Hz
HC1000-033/02500	3.3 kV	50/60Hz	2500kVA	3.3 kV	0-120Hz
HC1000-033/02740	3.3 kV	50/60Hz	2740kVA	3.3 kV	0-120Hz
HC1000-033/03140	3.3 kV	50/60Hz	3140kVA	3.3 kV	0-120Hz
HC1000-033/03500	3.3 kV	50/60Hz	3500kVA	3.3 kV	0-120Hz
HC1000-033/03890	3.3 kV	50/60Hz	3890kVA	3.3 kV	0-120Hz
HC1000-033/04690	3.3 kV	50/60Hz	4690kVA	3.3 kV	0-120Hz
Auxiliary a.c. input:					
Rated input voltage:		380-400V a.c.			
Rated input current:		16A			
Frequency:		50/60Hz			
Means of protection:		I			